

APAM · Melbourne Airport · CP24163 · Luminaire Schedule

Apron Lighting Luminaire Schedule: Type and Quantity by Pole

Pole by pole luminaire counts extracted from the apron lighting design drawing (Luminaire Type and Quantity, 15 June 2026) and reconciled to the drawing's own Scope of Works schedule. In scope poles carry the new luminaire count; out of scope poles are recorded but not counted.

POLE LOCATIONS

106

Distinct pole positions catalogued

IN SCOPE

64

42 recorded but out of scope

SCOPE LUMINAIRES

314

Reconciles exactly to Scope of Works

NET CHANGE VS EXISTING

+15

314 new against 299 existing

RECONCILIATION BY ZONE (IN SCOPE)

CONCOURSE / ZONE	POLES	LUMINAIRES
Bravo Concourse	10	43
Charlie Concourse	11	50
Delta Concourse	19	110
Northern Apron	4	28
Echo Concourse	6	23
Foxtrot Concourse	8	36
Zone 8	4	16
Zone 9	2	8
Total (Scope of Works)	64	314

● Matches the drawing schedule: 257 A0 + 21 A1 + 16 A2 + 20 A3 = 314

OUT OF SCOPE GROUPS

AREA / REASON		POLES
Tagged "Not In Scope" on pole (Qty *)		13
Golf Concourse (SGL)		13
Hotel Concourse (SFT)		8
Foxtrot Infill (FAL, F25SW)		8
Total out of scope		42

■ Full pole schedule

Filter by pole or zone...		All	In scope	Not in scope	106 poles shown		
POLE	CONCOURSE / ZONE	MOUNT HT	EXISTING	NEW	DELTA	STATUS	REASON
B21N	Bravo Concourse	M.H. 30m	4	5	+1	IN SCOPE	
B21S	Bravo Concourse	M.H. 30m	3	3	0	IN SCOPE	
B22S	Bravo Concourse	M.H. 30m	3	3	0	IN SCOPE	
B23N	Bravo Concourse	M.H. 30m	4	4	0	IN SCOPE	
B24S	Bravo Concourse	M.H. 30m	4	4	0	IN SCOPE	
B25N	Bravo Concourse	M.H. 30m	4	5	+1	IN SCOPE	
B26S	Bravo Concourse	M.H. 30m	6	6	0	IN SCOPE	
B27N	Bravo Concourse	M.H. 30m	4	5	+1	IN SCOPE	
B28E	Bravo Concourse	M.H. 30m	4	4	0	IN SCOPE	
B30N	Bravo Concourse	M.H. 30m	4	4	0	IN SCOPE	
C10N	Charlie Concourse	M.H. 30m	6	4	-2	IN SCOPE	
C10S	Charlie Concourse	M.H. 30m	4	4	0	IN SCOPE	
C11S	Charlie Concourse	M.H. 30m	6	6	0	IN SCOPE	

POLE	CONCOURSE / ZONE	MOUNT HT	EXISTING	NEW	DELTA	STATUS	REASON
C12E	Charlie Concourse	M.H. 30m	6	6	0	IN SCOPE	
C1S	Charlie Concourse	M.H. 30m	3	3	0	IN SCOPE	

E3D-APAM-RPT-003 · Rev A · J. Patman, RPEV · Issued 8 Jul 2026 · Issued for OES review
Empower3D Pty Ltd · ABN 23 684 621 190 · Electrical Contractor's Licence No. 1507107 · justin@empower3d.com.au
Schedule extracted from the supplied design drawing and reconciled to that drawing's control total. Quantities are subject to OES confirmation of the Qty A (B) convention (A = new, B = existing) before being relied upon for procurement.